

- 1 Q. Please show the monthly LOLH for the years shown in Haynes Schedule
2 XIV, similar to the format used in the table in IC-218 from the 2001 hearing.
3
4
5 A. Please see the attached table for the forecast monthly LOLH for the years
6 2001 through 2012. Actual data for 2001 and 2002 are not available.

Island Interconnected System Existing plus Committed Generating Capacity LOLH (hrs/yr)													
Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
2001*	0.65245	1.75175	0.12449	0.00115	0.00030	0.00000	0.00000	0.00000	0.00000	0.00006	0.01052	0.31526	2.85599
2002*	0.91660	2.37483	0.18754	0.00224	0.00068	0.00005	0.00000	0.00000	0.00000	0.00013	0.01754	0.46338	3.96298
2003	0.29592	0.10620	0.03294	0.00070	0.00002	0.00000	0.00000	0.00000	0.00000	0.00038	0.00505	0.16858	0.60978
2004	0.57767	0.19302	0.05170	0.00132	0.00005	0.00000	0.00000	0.00000	0.00000	0.00079	0.00871	0.24853	1.08180
2005	0.61604	0.23496	0.05630	0.00150	0.00006	0.00002	0.00000	0.00000	0.00000	0.00090	0.00964	0.26763	1.18705
2006	0.69676	0.26843	0.06455	0.00181	0.00008	0.00002	0.00000	0.00000	0.00000	0.00105	0.01118	0.30069	1.34457
2007	0.83340	0.32653	0.07977	0.00240	0.00011	0.00003	0.00000	0.00000	0.00000	0.00143	0.01425	0.36072	1.61864
2008	0.98049	0.34024	0.09659	0.00304	0.00014	0.00003	0.00000	0.00000	0.00000	0.00188	0.01770	0.42537	1.86548
2009	1.17392	0.47288	0.11826	0.00396	0.00019	0.00004	0.00000	0.00000	0.00000	0.00239	0.02212	0.50657	2.30033
2010	1.44726	0.59122	0.14921	0.00532	0.00026	0.00006	0.00000	0.00000	0.00000	0.00318	0.02856	0.61943	2.84450
2011	1.77991	0.73765	0.18844	0.00717	0.00042	0.00008	0.00000	0.00000	0.00000	0.00426	0.03704	0.75958	3.51456
2012	5.39522	1.92939	0.64526	0.03272	0.00251	0.00045	0.00000	0.00000	0.00000	0.01868	0.14053	2.23524	10.39999

* Based on the Long Term Planning Load Forecast 2001, as filed in reponse to IC-218 in Hydro's 2001 GRA.