

- 1 Q. Extend the table at page 3 of the answer to IC-65 NLH to include 1992, and
2 complete all information for all systems from 1992 to 2002.
3
4
5 A. Please refer to the attached table.

OPERATING LOAD IMPACTS OF HYDRO RURAL SYSTEMS INTERCONNECTED 1992 - 2000
Annual Energy Sales (at Bulk Delivery Point) and Peak Demand

Date of Interconnection		1992		1993		1994		1995		1996		1997		1998		1999		2000		2001		2002	
		MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW
1993	Petite Forte			149	137	474	150	492	172	485	171	486	182	484	184	485	172	502	173	519	168	517	168
1996	Roddickton/St. Anthony ¹									15350	9692	45939	10160	47720	10872	50214	11636	53052	11069	53583	10608	54478	11510
1996	Westport									288	424	1527	432	1553	432	1583	396	1626	468	1692	432	1809	504
1998	South East Bight ²													383	145	554	N/A	564	N/A	568	N/A	612	N/A
1999	La Poile ²															576	N/A	613	N/A	724	N/A	805	N/A
	Total	0	0	149	137	474	150	492	172	16123	10287	47952	10774	50140	11633	53412	12204	56357	11710	57086	11208	58221	12182
1998	Mud Lake ³															N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

1. Peaks for Roddickton/St. Anthony are an aggregate of non-coincident peaks
2. South East Bight and LaPoile loads are estimated based on sales to customers.
3. Mud Lake is not metered separately from Happy Valley