

1 Q. Regarding Exhibit JRH-3 page 22 indicates that NP is “now relocating a
2 portion of their thermal generation (15 MW gas turbine) elsewhere on the
3 system”. Please indicate whether the Tables 2-1, 3-1, 3-2 and 3-3 at pages
4 5, 9 and 11-13 of this exhibit reflects the Burin Peninsula generation prior to
5 or after the relocation.

6
7
8 A. The tables in Exhibit JRH-3 assumes that the 15 MW gas turbine has been
9 relocated to the Bonavista Peninsula.