

1    Q.    Regarding Exhibit JRH-3 please quantify the amount of capacity added to the  
2           system since January 30, 2003, and all additional amounts expected to be  
3           fully operational by 2004.

4

5

6    A.    On January 30, 2003 the Corner Brook Cogeneration unit went into  
7           commercial operation at 15 MW. Since that time an additional 40 MW has  
8           been added from Granite Canal and an additional 5 MW from the Exploits  
9           River project. Another 27.3 MW will be added from the Exploits River project  
10          prior to the end of 2003.