

1 Q. Regarding Exhibit JRH-3 please confirm that Hydro's 2003 additions to
2 capacity (since the January 30, 2003 operation of Hawke's Bay and St.
3 Anthony diesels) totals 87.3 MW.

4

5

6 A. The total capacity additions since the Hawke's Bay and St. Anthony diesels
7 were operated on January 30, 2003 is 60 MW. An additional 27.3 MW is
8 expected prior to the end of 2003 for a total of 87.3 MW by the end of 2003.