

1     Q.     Roberts, Schedule II - please quantify the savings in fuel costs arising from  
2            achieving a 648 kW.h/bbl efficiency (per Haynes, Schedule VII) compared to  
3            a forecast 615 kW.h/bbl in P.U. 7 (2002-2003)

4

5

6     A.     Please refer to IC-207. There was a \$2,464,000 saving to the RSP and an  
7            overall saving of \$6,124,000.