

- 1    Q.    Please indicate whether any adjustments were made to reflect the new  
2           capacity brought into service, and the decreased likelihood of relying on  
3           these plants now that the new generation has been brought on-line.  
4  
5
- 6    A.    There was a reduction reflected in the forecast energy produced from gas  
7           turbines in 2004 from 2003 to reflect the new capacity. A forecast of 420  
8           MWh for peaking was assumed in 2003 while for 2004 it was reduced to 20  
9           MWh.