

1 Q. Regarding Haynes Table 8 - Please confirm that Budgell Schedule XII from
2 the 2001 application reflected peaks that were 46 MW lower than would
3 otherwise have been expected had there been no Interruptible B program in
4 place.

5

6

7 A. The peak loads provided in Budgell, Schedule XII are not 46 MW lower than
8 would otherwise have been expected had there been no Interruptible B
9 program in place. The peak demands in Budgell, Schedule XII from the 2001
10 GRA include the peak load forecast for Abitibi Stephenville (i.e. the 46 MW is
11 not netted off the Abitibi Consolidated Company of Canada Stephenville
12 peak load forecast).