

1 Q. Regarding IC-276 NLH: Please show the effect on Haynes Table 8 for the
2 Island Interconnected system assuming all GNP generation was
3 disconnected from the Island Interconnected System..

4

5

6 A. Please refer to the following table assuming all GNP generation was
7 disconnected from the Island Interconnected System in 2004:

Island Interconnected System Near Term Capability Requirements <i>Assuming: all GNP Generation Disconnected in 2004</i>						
<u>Load Forecast</u>			<u>Existing plus Committed System</u>			
<u>Year</u>	<u>Peak</u>	<u>Energy</u>	<u>Net Capacity</u>	<u>Firm Capability</u>	<u>LOLH</u>	<u>Energy Balance</u>
	(MW)	(GWh)	(MW)	(GWh)	(Hrs/Yr)	(GWh)
2003	1,578	8,441	1,919	8,706	0.6	265
2004	1,602	8,504	1,904	8,705	1.4	201
2005	1,607	8,512	1,904	8,705	1.6	193
2006	1,613	8,556	1,904	8,705	1.8	149
2007	1,624	8,606	1,904	8,705	2.1	99
2008	1,634	8,653	1,904	8,705	2.5	52
2009	1,643	8,716	1,904	8,705	3.0	(11)
2010	1,654	8,793	1,904	8,705	3.7	(88)
2011	1,666	8,865	1,904	8,705	4.6	(160)
2012	1,728	9,309	1,904	8,705	13.2	(604)