

1 Q. Regarding IC-276 NLH: Please show the effect on Haynes Table 8 for the
2 Island Interconnected system assuming 1) all GNP loads were disconnected
3 from the Island Interconnected System, 2) all GNP generation was
4 disconnected from the Island Interconnected System.

5

6

7 A. Please refer to the following table assuming all GNP load and generation
8 was disconnected from the Island Interconnected System in 2004:.

**Island Interconnected System
Near Term Capability Requirements**
*Assuming: all GNP Generation Disconnected in 2004, and
all GNP Loads Disconnected From the Island Interconnected System***

<u>Year</u>	<u>Load Forecast</u>		<u>Existing plus Committed System</u>		<u>LOLH</u>	<u>Energy Balance</u>
	<u>Peak</u>	<u>Energy</u>	<u>Net Capacity</u>	<u>Firm Capability</u>		
	(MW)	(GWh)	(MW)	(GWh)	(Hrs/Yr)	(GWh)
2003	1,578	8,441	1,919	8,706	0.6	265
2004	1,563	8,319	1,904	8,705	0.7	386
2005	1,568	8,327	1,904	8,705	0.8	378
2006	1,574	8,372	1,904	8,705	0.9	333
2007	1,584	8,422	1,904	8,705	1.1	283
2008	1,594	8,469	1,904	8,705	1.3	236
2009	1,604	8,531	1,904	8,705	1.6	174
2010	1,614	8,606	1,904	8,705	1.9	99
2011	1,626	8,677	1,904	8,705	2.4	28
2012	1,688	9,120	1,904	8,705	7.4	(415)

** A provision for the GNP load is removed from the 2003 Planning Load Forecast in years 2004 through 2012