

1 **Q. Please provide values for Chart 5 in Perry and Henderson (i.e., what were the peak**  
2 **demands and energy requirements for each year).**

3  
4 A. The normalized energy requirements and normalized peak demands used to create Chart  
5 5 of the *Prefiled Evidence: Perry and Henderson* are provided in Table 1 below.  
6  
7

8 **Table 1**  
9 **Newfoundland Power Normalized Energy Requirements**  
10 **And Normalized Peak Demand**  
11 **1992 - 2002**

12	13	14	15	16
	Year	Normalized Energy Requirements (GWH)	Normalized Peak Demand (MW)	
17	1992	4,482.5	996.9	
18	1993	4,512.6	1,014.9	
19	1994	4,598.1	1,040.3	
20	1995	4,609.5	1,110.2	
21	1996	4,658.9	1,100.4	
22	1997	4,667.7	1,027.0	
23	1998	4,688.3	1,097.8	
24	1999	4,741.9	1,041.7	
25	2000	4,855.4	1,084.5	
26	2001	4,911.0	1,135.9	
27	2002	5,028.0	1,107.3	
28				