

- 1 Q. What are the present generation costs on a per kilowatt hour basis for energy
2 consumed on the Labrador Interconnected System?
3
4
5 A. Please see attached.

Newfoundland and Labrador Hydro
2004 Forecast Cost of Service

Line No.	Description	Amount	Source/Notes
1	Production Demand Costs	3,825,587	Exhibit RDG-1, page 87, Column 3
2	Production Energy Costs	1,339,533	Exhibit RDG-1, page 87, Column 4
3	Total Production Costs	5,165,120	
4	kilowatt hours	947,700,000	Exhibit RDG-1, page 97, Column 4, Line 12
5	Cents per kilowatt hour	0.5450	Line3/Line4*100