

1 Q. Please explain how the 230 kV busses at Churchill Falls are connected to the
2 138 kV lines that run from Churchill Falls to Happy Valley/Goose Bay.
3 Please provide a one-line diagram of the Churchill Falls facilities involved.

4
5

6 A. The 230 kV buses at Churchill Falls are connected to the 138 kV
7 transmission line that runs from Churchill Falls to Happy Valley/Goose Bay
8 via 230 kV disconnect switches and two 230/138 kV transformers. The
9 attached figure provides the single line diagram of Churchill Falls.

