

1    Q.    Explain in detail the change in Hydro's forecast costs related to the Wabush  
2           Terminal Substation from One Hundred and Six Thousand Two Hundred and  
3           Thirty Five (\$106,235.00) Dollars in Hydro's original filing to Four Hundred  
4           and Thirty Eight Thousand and Twenty (\$438,020.00) Dollars.

5  
6  
7    A.    The change in forecast is due to expenses previously not included related to  
8           inspection of the synchronous condensers (\$89,000), 46 kV pothead  
9           replacements (\$30,000) and control replacements for the synchronous  
10          condensers (\$500,000). Hydro is required to pay 53.6% of these costs which  
11          equates to \$331,784.