1	Q.	(Re: Financial Consulting Report on 2003 GRA page 33, lines 1-2)
2	-	
3		Please explain how 633 kWh/bbl for the period January 1996 to December 2003 was
4		derived from NP-208. Shouldn't the answer be 625 kWh/bbl given that the actual
5		and projected production for Holyrood in 2003 is 2,127 GWh using 3,363 thousand
6		barrels?
7		
8	A.	The conversion factor of 633kWh/bbl indicated in NP-208 represents a forecast
9		conversion factor for 2003 using the actual production and actual barrels used from
10		January 1, 2003 to June 30, 2003 and assuming a factor of 624 kWh/bbl from July to
11		December, 2003.
12		
13		Using the information in the table presented in response to NP-74 and the forecast
14		conversion factor of 633 kWh/bbl for 2003 provided in the response to NP-208, we
15		confirm the weighted average conversion factor for the period 1996 to 2003 would be
16		625 kWh/bbl .
17		
18		For clarification, the reference on page 33, lines 1-2 of our report should only refer to
19		actuals from January to June 2003.