

- 1 Q. Is there a situation where any new additional load on the Island
2 Interconnected System does not adversely affect the system with
3 respect to the application of the generation planning criteria? If so
4 please describe.
5
6 A. Yes. Non-firm loads do not adversely affect the system with respect to
7 the application of the generation planning criteria. Non-firm or
8 interruptible loads are, by definition, not served if they would result in
9 generation constraints.