

# **Newfoundland & Labrador Hydro**

## **2003 General Rate Application**

### **Towns of Labrador City and Wabush Responses to Hydro Information Requests**

#### **Request**

NLH-251 LC      With reference to Page 5 last paragraph, if the transmission lines served from the 230 KV bus at Churchill Falls are not interconnected, what immediately happens to load fed by these lines when supply is interrupted?

#### **Response**

If supply at Churchill Falls were totally interrupted, the different loads connected to that power supply would not be served. However, Hydro has first call on CF(L)Co output, so in the case of a partial Churchill Falls outage, the first load to be reduced would be power exported to Québec.