

# **Newfoundland & Labrador Hydro**

## **2003 General Rate Application**

### **Towns of Labrador City and Wabush Responses to Hydro Information Requests**

#### **Request**

NLH-252 LC      With reference to Page 5 last paragraph, please describe what makes an “interconnected “ system?

#### **Response**

An “interconnected” system is one in which power flows between the systems. In this case, power flows from a common source (Churchill Falls) out over separate transmission lines to Labrador East and Labrador West, with no interaction between the flow on one line and the flow on another.