

Newfoundland & Labrador Hydro

2003 General Rate Application

Towns of Labrador City and Wabush Responses to Hydro Information Requests

Request

NLH-258 LC With reference to Page 1, first paragraph, isn't it true that on any interconnected system with radial lines to communities the nature of the facilities serving the communities is different? Please explain your response.

Response

The nature of the delivery facilities is not necessarily any different, usually being subtransmission and distribution lines. If the system is truly interconnected, the power supply and transmission facilities are common.