

NLH-33 IC
2003 NLH General Rate Application

Page 1 of 1

- 1 Q. Under terms of the expired Interruptible "B" contract, how many times
2 in one day could Hydro interrupt firm power?
3
4 A. The Interruptible B rate contract provides for one interruption per day,
5 between the hours of 0800 and 2200 for a maximum of 10 consecutive
6 hours.