

- 1 Q. Under terms of the expired Interruptible "B" contract, could Hydro
2 request an interruption before running any of its gas turbines?
3
4 A. The Interruptible B rate contract provides that an interruption
5 requirement to Abitibi would be dispatched after two of the three gas
6 turbines had been started and loaded.