

1 Q. Under terms of the expired Interruptible "B" contract, what limitations
2 were placed on total energy interrupted over a 3 day and 5 day
3 period?
4

5 A. The Interruptible B rate contract allowed maximum energy
6 interruptions of 690 MW.h over a three day period and 920 MW.h over
7 a five day period.