

Perry and Henderson

Q. Please provide the NP hydraulic generation at the time of NP's native peak for each year from 1993 to 2002. Include the average of these values.

A. Newfoundland Power's hydraulic generation at the time of its native peak for each year from 1993 to 2002 is provided in Table 1 below.

Table 1
Newfoundland Power's Native Peaks

Year	Date	Time	Peak (MW)	Hydraulic Generation at Peak (MW)
2002	FEB 15/2003	18:15	1,135,245	77.0
2001	JAN 31/2002	18:00	1,194,687	82.0
2000	DEC 24/2000	17:52	1,022,600	68.0
1999	JAN 06/2000	17:45	1,017,109	59.0
1998	DEC.23/1998	18:00	1,044,909	26.0
1997	JAN. 7/1998	17:30	1,068,779	53.0
1996	DEC. 31,1996	17:15	1,080,840	73.0
1995	JAN. 16,1996	17:45	1,123,298	69.0
1994	FEB. 13,1995	18:00	1,030,985	46.0
1993	FEB. 09,1994	08:15	1,098,337	31.0
Average				58.4

Newfoundland Power's hydraulic generation at peak does not represent the capability of the hydraulic generation to meet Newfoundland Power's native peak. Newfoundland Power would only have its full hydraulic generation operating at peak if requested to do so by Hydro.