

1 Q. What was the effective annual credit per kW and the amount of capacity that
2 was available to Hydro through the Industrial Interruptible “B” rate?

3

4

5 A. Under the Interruptible ‘B’ contract with ACCC-Stephenville there was a
6 maximum of 46,000 kW of interruptible capacity available for up to 25
7 occasions per year only for the four month period December to March at an
8 effective annual cost of \$28.2/kW.