

- 1 Q. Please reproduce Table 8 of the Production evidence with the LOLH revised
2 to reflect what the LOLH would be with an additional 46 MW of interruptible
3 load.
4
5
- 6 A. The attached table shows Table 8 of the Production evidence revised to
7 reflect the addition of 46 MW of interruptible load having the same conditions
8 as the ACCC-Stephenville contract:

Island Interconnected System Near Term Capability Requirements With 46 MW Interruptible Load						
<u>Load Forecast</u>			<u>Existing plus Committed System</u>			
<u>Year</u>	<u>Peak</u>	<u>Energy</u>	<u>Net Capacity</u>	<u>Firm Capability</u>	<u>LOLH</u>	<u>Energy Balance</u>
	(MW)	(GWh)	(MW)	(GWh)	(Hrs/Yr)	(GWh)
2003	1,578	8,441	1,919	8,706	0.6	265
2004	1,602	8,504	1,919	8,706	0.9	202
2005	1,607	8,512	1,919	8,706	1.0	194
2006	1,613	8,556	1,919	8,706	1.1	150
2007	1,624	8,606	1,919	8,706	1.3	100
2008	1,634	8,653	1,919	8,706	1.5	53
2009	1,643	8,716	1,919	8,706	1.9	(10)
2010	1,654	8,793	1,919	8,706	2.4	(87)
2011	1,666	8,865	1,919	8,706	3.0	(159)
2012	1,728	9,309	1,919	8,706	9.2	(603)