| 1 | Q. | Further to NP-75 NLH: The conversion factors in January 1999 and March |
|----|----|---|
| 2 | | 1999 were 556.7 kWh/bbl and 531.4 kWh/bbl respectively. The average |
| 3 | | conversion factors for the same months in the other years provided in the |
| 4 | | response were 635.6 kWh/bbl in January and 631.1 kWh/bbl in March. |
| 5 | | Calculate a 1999 pro-forma fuel conversion factor by reducing the fuel |
| 6 | | consumed in 1999 to reflect a 635.6 kWh/bbl efficiency in January and 631.1 |
| 7 | | kWh/bbl efficiency in March. |
| 8 | | |
| 9 | | |
| 10 | A. | By applying a January conversion factor of 635.6 kWh/bbl and a March |
| 11 | | factor of 631.1 kWh/bbl to the yearly calculation for conversion factors, the |
| 12 | | pro-forma fuel conversion factor for 1999 is 598.8 kWh/bbl. |