

1 Q. Further to NP-205 NLH: if the recalculated 2004 Holyrood conversion factors
2 was used to determine the 2004 revenue requirement, quantify the dollar
3 impact.

4

5

6 A. Using a conversion factor of 625.8 kWh per barrel in 2004 the revenue
7 requirement would be reduced by approximately \$240,000.