

1 Q. **Grant Thornton's Prefiled Evidence**

2 Page 31, lines 20-23 – Should the forecast conversion factor for Holyrood
3 referred to in Request for Information NP-267 NLH be adjusted further to
4 reflect the 2 kWh/bbl efficiency improvement estimated with respect to the
5 water lance installation?
6
7

8 A. The addition of the water lance and reheater tubing on Unit 3 is expected to
9 increase the plant efficiency by 2 kWh/bbl over what it would otherwise be.
10

11 However, as described in response to NP-267 NLH, this was considered in
12 Hydro's recommendation for the use of 624 kWh/bbl in 2004.