

1     Q.     Transmission and Rural Operations evidence, Schedule IV shows that the  
2           installed capacity for Little Bay Islands increased from 1,250 kW in 2000 to  
3           1,700 kW in 2002. Was the increase in capacity installed in response to a  
4           request for service from the seafood processing facility referred to on page  
5           32, lines 21 to 23 of the Production evidence?

6  
7  
8     A.     Yes, the increase in capacity was installed in response to a request for  
9           service from the seafood processing facility.