

1 Q. Please reconcile 4,234 GWh shown in the Production evidence, page 29, line
2 28 with the figures in Table 7.

3

4

5 A. The difference between 4,234 GWh and the total figure of 4,458 GWh in
6 Table 7 is 224 GWh which is the average energy capability of Granite Canal.
7 Granite Canal was excluded from the 30-year average value because it is
8 based on a longer record (starting in 1950) from simulations done in support
9 of the Granite Canal project. Hydro did not change this estimate to a 30-year
10 value because the method used for the other plants cannot apply to a plant
11 with no operating history. Also, the model used in support of the Granite
12 project would not be applicable as an operating model and therefore was not
13 modified to look at the most recent 30 years inflow record. The Granite
14 Canal capability will be reviewed in conjunction with simulations carried out
15 of all plants using a model as recommend by SGE Acres.