

1 Q. Provide the actual production efficiency (in kWh per barrel) for the Holyrood  
2 Generating facility by month and year for each year from 1998 to current and  
3 forecast for the remainder of 2003 and 2004 (Production evidence, Schedule  
4 VII).

5

6

7 A. The following table provides the actual Holyrood fuel conversion factor by  
8 month and annually from January 1998 to June 2003. The forecast factor for  
9 the remainder of 2003 and 2004 is 624 kWh/bbl.

**Holyrood Monthly and Annual Conversion Factors  
(January 1998 to June 2003)**

	1998	1999	2000	2001	2002	2003
January	622.1	556.7	640.3	628.7	636.5	650.4
February	647.9	642.5	571.2	619.9	667.8	641.4
March	641.7	531.4	600.2	624.1	644.9	644.4
April	611.8	522.9	581.8	635.7	652.8	639.3
May	594.2	547.2	569.3	611.5	645.7	605.8
June	478.1	196.3	0	613.6	641.7	588.5
July	0	0	0	605.7	630.0	
August	0	542.2	0	613.1	624.8	
September	0	585.1	607.4	626.9	645.3	
October	560.2	572.0	644.8	648.6	647.6	
November	572.3	624.6	588.9	647.4	654.4	
December	591.2	594.2	633.3	651.9	649.3	
Annual	618.8	577.1	609.6	632.9	648.5	