

Table 8

**Island Interconnected System
Near Term Capability Requirements
*Bay D'Espoir Unit 7 (154 MW) Removed From Service***

<u>Year</u>	<u>Load Forecast</u>		<u>Existing plus Committed System</u>		<u>LOLH</u>	<u>Energy Balance**</u>
	<u>Peak</u>	<u>Energy</u>	<u>Net Capacity</u>	<u>Firm Capability**</u>		
	(MW)	(GWh)	(MW)	(GWh)	(Hrs/Yr)	(GWh)
2003	1578	8441	1,765	8,706	12.1	265
2004	1602	8504	1,765	8,706	16.6	202
2005	1607	8512	1,765	8,706	18.1	194
2006	1613	8556	1,765	8,706	20.0	150
2007	1624	8606	1,765	8,706	22.9	100
2008	1634	8653	1,765	8,706	24.9	53
2009	1643	8716	1,765	8,706	29.9	(10)
2010	1654	8793	1,765	8,706	35.2	(87)
2011	1666	8865	1,765	8,706	41.3	(159)
2012	1728	9309	1,765	8,706	95.9	(603)

** No adjustment for loss of energy capability due to the removal of Bay D'Espoir Unit #7