

1 Q. Ref: Direct Testimony of James Haynes, Eric Downton and Kenneth
2 McDonald, p.4, lines 17-20. Does Hydro expect to improve operational
3 efficiencies at the Holyrood Plant as a result of its replacement/upgrade of
4 the plant computerized control system? If so, please provide detail on any
5 analysis completed on the same.

6
7
8 A. In discussions with the manufacturer they advised that some utilities have
9 verbally noted minor increases in efficiency due to faster processing times,
10 but they were unable to quantify these improvements, and none were
11 credited in evaluating the alternatives.