

1 Q. **Re: p. B-24** Does an existing regulation require that these valves be
2 replaced in this year? If so, please refer to the specific regulation.

3

4

5 A. These valves are not being replaced but added to the existing system as
6 required by the Storage and Handling of Gasoline and Associated Products
7 Regulations. The regulations do not require they be added in 2005.

8 However, the system must be modified with these valves as a condition of
9 the Certificate of Approval by the Department of Environment and

10 Conservation.