

1 Q. **Re: p. B-77** Does this Project contemplate permanent installation of fall  
2 protection equipment at all sites regardless of the number of times that such  
3 equipment may be required to be used?  
4

5

6 A. No, only those sites accessed on a frequent basis and which have a high  
7 potential for injury, should a fall occur, are to be fitted with permanent  
8 installations. An example would be vertical fuel storage tanks, which have to  
9 be accessed on a weekly basis to obtain measurements in order to comply  
10 with fuel reconciliation legislation. Structures such as buildings and power  
11 transformers, which are accessed on a less frequent basis, may be able to  
12 share equipment which is transported to the site and installed when required.  
13 Other low priority structures, such as line depots or storage sheds that are  
14 accessed very infrequently and where a delayed access will not have any  
15 serious affect on Hydro's provision of service may be addressed by  
16 temporary measures as the need arises.