

1 Q. **Re: p. B-9** Do the existing Regulations require replacement of the tanks in
2 2005?

3

4

5 A. The existing regulations do require the tanks to be compliant with
6 regulations. Three fuel storage tanks at the Upper Salmon Development do
7 not meet the Provincial Gasoline and Associated Products (GAP)
8 Regulations and they are in contravention of Canadian Council of Ministers
9 of Environment (CCME), Environmental Code of Practice for Underground
10 Storage Tank Systems Containing Petroleum Products. The existing tanks
11 do not have any means of quantifying the amount of fuel used by the diesel
12 generators for reconciliation purposes and do not have adequate leak
13 containment or detection provisions.

14

15 Hydro does not have a certificate of approval for these tanks which is
16 required by legislation.