

1 Q. **Re: p. B-110** Indicate the size of the transformers at Bay d’Espoir and the
2 quantity of oil in each which is intended to be refurbished by the equipment
3 referred to in this Explanation as well as the sizes of the other units for which
4 the equipment will be used.

5

6

7 A. There are four (4) transformers at Bay d’Espoir yet to be refurbished. These
8 units are rated 64/85 MVA and each contain approximately 38,000 liters of
9 oil.

10

11 For the 17 high priority units stated in the explanation, the sizes range from
12 40/50 MVA (40,000 liters) to 75/100/125 MVA (50,000 liters).

13

14 For the 67 units showing parameters outside the guidelines and for the total
15 161 units on the bulk electrical system, the sizes range from 10 MVA (15,500
16 liters) to 190 MVA (50,000 liters).