

1 Q. **Re: p. B-110** Indicate the anticipated service life of the unit to be acquired
2 under this project.

3

4

5 A. The anticipated depreciable service life for the oil reclamation equipment is
6 ten (10) years. Ten years is the average service life that Hydro uses for this
7 type of equipment. The actual operational service life for the equipment is
8 expected to be considerably longer.