

1 Q. **Re: p. B-143** Provide particulars of any failures or other demonstrated
2 unreliability of the RTUs for each site.

3

4

5 A. The particulars of the failures for the past 5 years on each RTU are:

6

7 Bay d'Espoir Plant RTU

8 CPU Card 2

9 Sequence of Events Card 1

10 Communications Card 1

11

12 Bay d'Espoir Terminal Station

13 Telemetry Failures 3

14 Status Card 1