

1 Q. **Re: p. B-11** Provide number of maintenance occurrences per year for each
2 valve replaced to date for a five year period prior to replacement and to date.

3
4
5 A. **Spherical valve #1**

6 The new control system was placed in operation on July 4, 2003. Since July
7 4, 2003 to present there have been two (2) maintenance occurrences. From
8 July 4, 1998 to July 4, 2003 there were twenty-six (26) maintenance
9 occurrences.

10

Year	July 4 1998	1999	2000	2001	2002	July 4 2003	July 4 2003	2004
Occ.	0	10	5	5	5	1	0	2

11
12
13 **Spherical valve #2**

14 The new control system was placed in operation on August 17, 2002. Since
15 August 17, 2002 to present there have been two (2) maintenance
16 occurrences. From August 17, 1997 to August 17, 2002 there were twenty-
17 one (21) maintenance occurrences.

18

Year	Aug 17 1997	1998	1999	2000	2001	Aug 17 2002	Aug 17 2002	2003	2004
Occ.	1	6	0	6	7	1	1	0	1

19
20
21 **Spherical valve #3**

22 The new control system was placed in operation on June 18, 2004. Since
23 June 18, 2004 to present there have been zero (0) maintenance

occurrences. From June 18, 1999 to June 18, 2004 there were twelve (12) maintenance occurrences.

Year	June 18 1999	2000	2001	2002	2003	June 18 2004	June 18 2004
Occ.	3	2	4	2	1	0	0

Spherical valve #4

The new control system was placed in operation on August 31, 2001. Since August 31, 2001 to present there have been three (3) maintenance occurrences. From August 31, 1996 to August 31, 2001 there were seventeen (17) maintenance occurrences.

Year	Aug 31 1996	1997	1998	1999	2000	Aug 31 2001	Aug 31 2001	2002	2003	2004
Occ.	0	6	6	0	2	3	1	0	2	0