

1 Q. **RE: p. B-25** Restate the Project Costs to break out the costs of
2 construction of the new building proposed to house the diesel generator,
3 and explain why the installation of the generator necessitates the
4 construction of the building.

5

6

7 A. The cost of the new building is estimated at \$19,000.

8

9 The building is required to house the generator and the additional controls as
10 the unit is not an outdoor diesel set and because there is not suitable and
11 sufficient space in the existing facility to house it.