1	Q.	Re: p. B-20 How long has the existing water sprinkler system been in place
2		with the risk of damage as described in the Operating Experience in this
3		Explanation?
4		
5		
6	A.	The existing water sprinkler system predates the use of this area for the
7		microwave equipment, which was installed in 2002.