

1 Q. Regarding the report titled *A Performance Target Methodology for the*
2 *Distribution Feeders of the Newfoundland and Labrador Hydro Electrical*
3 *System* (Section H, Tab 4), with specific reference to the planned
4 expenditures on Hawke's Bay 20101 (B-65, Upgrade Distribution Feeders)
5 and South Brook 10107 (B-72, Replace Insulators), please explain why
6 Hydro, in assessing feeder performance, considers all outage statistics for
7 the feeder, as opposed to considering only unscheduled distribution outages.

8

9

10 A. The failure modes of the feeders are distinctive and cannot be evaluated
11 properly or completely by simply considering the 'unscheduled' outages.

12

13 Feeder performance statistics are a function of various factors and events
14 under the two main categories of 'scheduled' and 'unscheduled'. It is
15 necessary to study the data in both categories in order to determine the true
16 and complete 'character of the feeder'.

17

18 Under 'scheduled' outages there are two main subsets; 1) customer related
19 (i.e. connections or disconnections); and 2) corrective maintenance. The
20 work content under the corrective maintenance subset must be studied and
21 correlated with the components of the 'unscheduled' outages to completely
22 define what upgrade work is necessary to improve performance.

23

24 For example, for the two projects named, the study of the unscheduled
25 outages concluded that one of the major causes of poor performance (that
26 could be corrected) was defective equipment. And, of course, defective
27 equipment is more often than not insulators. It was necessary to confirm this
28 conclusion by studying the corrective maintenance work under 'scheduled'

1 outages to make sure that the insulators had not already been replaced. Had
2 that been the case, the more appropriate action would be to defer further
3 work until the benefit of the 'scheduled' replacements began to show in the
4 performance statistics. For the two projects named, the study of the
5 'scheduled' outages confirmed there were still a significant number of
6 defective insulators contributing to poor performance. Therefore, the
7 proposal was made for the widespread replacement. Had the 'scheduled'
8 outages not been studied, this fact would have been overlooked.

9
10 Thus, the study of the 'scheduled' aspects of the performance indices must
11 be done in concert with the 'unscheduled' aspects in order to determine the
12 full and complete performance profile, and to define what work will be
13 effective in improving performance. Concentration on the 'unscheduled'
14 outages, only, would not be an incomplete analyzing strategy.