

1 Q. With regard to the response to CA 56 NLH, please provide all information
2 related to your review of reliability performance relative to available
3 comparable utilities.

4

5

6 A. Please refer to CA 4 NLH for an explanation of why information for
7 comparable utilities reported to the CEA cannot be provided at this time.
8 However, a comparison can be made to NP service continuity data provided
9 in response to CA 186 NLH in the 2005 Inter-utility reliability committee
10 review. Their performance indicators and Hydro's are repeated in the
11 following table for ease of reference. Please note that NP does not report
12 transmission delivery point reliability measures to enable a comparison.

**Distribution Service Continuity Statistics
2001 to 2005**

System Average Interruption Frequency Index (Interruptions per Customer)

Utility	2001	2002	2003	2004	2005
Newfoundland Power	3.99	4.76	5.2	3.58	3.21
Newfoundland & Labrador Hydro - Interconnected	6.58	7.35	7.18	4.89	5.43
Newfoundland & Labrador Hydro - Isolated	13.57	23.75	12.88	13.25	8.79

System Average Interruption Duration Index (Hours per Customer)

Utility	2001	2002	2003	2004	2005
Newfoundland Power	3.89	4.54	5.28	4.87	3.53
Newfoundland & Labrador Hydro - Interconnected	10.42	12.29	11.99	10.10	9.15
Newfoundland & Labrador Hydro - Isolated	8.44	22.84	11.32	18.92	6.27