

1 Q. With regard to Exhibit JRH-1 on Key Performance Indicators, please respond
2 to the following:

3 a. What other transmission utilities track SAIDI and SAIFI and SARI?

4 b. What reliability-related performance metrics are commonly reported
5 by other transmission utilities?
6
7

8 A. a. As of 2004, nine other Canadian transmission utilities reported this
9 data to the Canadian Electricity Association (CEA). These utilities are:
10

- 11 • Altalink Management Limited
- 12 • ATCO Electric
- 13 • EPCOR
- 14 • Hydro One
- 15 • Trans-Energie
- 16 • Manitoba Hydro
- 17 • New Brunswick Power
- 18 • BC Transmission Corporation
- 19 • SaskPower
20

21 While other Canadian utilities outside of the CEA may track these
22 performance indicators, Hydro is unaware of such utilities.
23

24 b. SAIDI and SAIFI are the most common reliability-related performance
25 metrics reported by other transmission utilities. SARI does not
26 normally get referenced, as it is the ratio of the two primary measures
27 (SAIDI and SAIFI).