

- 1 Q. With regard to Exhibit JRH-1 on Key Performance Indicators, please provide
2 the table on page 5 showing Hydro's weighted capability factor with the effect
3 of the asbestos abatement program at Holyrood removed.
4
5
- 6 A. Hydro's weighted average capability factor would have been approximately
7 89% with the effects of the asbestos abatement program removed. The
8 chart on page 5 of Exhibit JRH-1 reproduced with the modified 2005
9 weighted capability factor is provided below.

