

1 Q. With respect to the 2005 Key Performance Indicators report, please provide  
2 the hydraulic generation and million cubic meters of water information used  
3 to calculate the Hydraulic Conversion Factor metric for 2001 through 2005 on  
4 page 13 of the report. Please describe all operational measures Hydro can  
5 take to improve its hydraulic conversion factor, regardless of hydraulic  
6 conditions. Please also indicate the volumes spilled in each of 2001-2005.

7  
8  
9 A. Hydraulic generation and turbine use information used as the basis of the  
10 Key Performance Indicators (KPIs) is provided below. The KPI is for Bay  
11 d'Espoir conversion factor only.

Year	Production (GWh)	Turbine Use (MCM)	Conversion Factor (GWh/MCM)
2001	2392.4	5507.7	0.434
2002	2351.7	5387.2	0.437
2003	2497.6	5736.3	0.435
2004	2832.5	6509.9	0.435
2005	2840.1	6511.9	0.436

13  
14 With respect to the operational measures that Hydro can take to improve its  
15 hydraulic conversion factors, please refer to NP 38 NLH for a list of  
16 measures that Hydro has implemented for this same purpose.

17  
18 The following table provides the volume of spill for the period 2001 to 2005.

<b>Annual Total Spill by Reservoir (MCM)</b>					
<b>Reservoir</b>	<b>2001</b>	<b>2002</b>	<b>2003</b>	<b>2004</b>	<b>2005</b>
Long Pond	0	0	0	0	0
Upper Salmon	0	0	0	0	1
Granite (Bypass)	0	0	0	54	103
Granite (Spillway)	0	0	289	1	30
Burnt Dam	0	0	103	0	7
Victoria	0	0	6	0	0
Hinds Lake	0	0	0	0	0
Cat Arm	0	0	0	0	63
Paradise River	151	109	174	250	155