

1 Q. Please indicate any occasions since January 2003 when NP's generation  
2 has been dispatched by Hydro to cover system capacity peaks, including the  
3 date and time, duration, MW and MWh dispatched and any amounts paid by  
4 Hydro to NP.

5

6

7 A. The following table identifies all occasions since January 2003 when Hydro  
8 requested NP generation be dispatched to cover system generation capacity  
9 requirements.

10

Date	Time	Source	Energy (kWh)	Amount paid by NLH
January 8, 2004	16:55- 18:18	Hydro maximized		
March 18, 2004	16:13- 20:18	Hydro maximized		
September 2, 2005	13:00- 13:50	Greenhill GT Mobile GT	14,402	\$3,663
	12:11- 14:00	Hydro maximized		
September 13, 2005	16:40- 21:51	Hydro maximized		
September 21, 2005	18:56- 22:28	Hydro maximized		
January 23, 2006	7:22- 19:30	Diesels and GTs	385,393	\$83,452
	7:00- 19:30	Hydro maximized		
February 25, 2006	17:40- 18:35	Hydro maximized		

11