

1 Q. Does Hydro's decision to extend the turbine overhaul period from six to nine
2 years apply to the Holyrood generating facility? (CA-122 NLH)

3

4

5 A. Hydro's decision to extend the turbine overhaul period from six to nine years
6 applies to the steam turbines at the Holyrood generating facility.