

- 1 Q. Provide the calculation of the interconnected system load factor for each year
2 from 1996 to 2007 forecast.
3
4
5 A. Please see table below.

Interconnected Island System Load Factor (Winter Peak)			
	Island Net Generation (GWh)	Peak (MW)	Load Factor
1996	7,671	1,445	60.6%
1997	7,983	1,491	61.1%
1998	7,310	1,465	57.0%
1999	7,728	1,453	60.7%
2000	8,057	1,443	63.7%
2001	7,939	1,592	56.9%
2002	8,221	1,595	58.8%
2003	8,340	1,572	60.6%
2004	8,496	1,598	60.7%
2005	8,318	1,480	64.2%
2006 F	8,079	1,569	58.8%
2007 F	8,150	1,583	58.8%
Island net generation includes Hydro generation, purchases, and customer generation. Winter peak covers the winter season of November through March.			